


TOWN OF BOURNE BOARD OF HEALTH

24 Perry Avenue
Buzzards Bay, MA 02532



Cynthia A. Coffin
Health Agent

To: Thomas Pappas
14 Bosuns Ln
Bourne, MA 02532

Re: Title transfer inspection for 10 Foretop Rd, Bourne, MA
Date: January 16, 2014

Dear Mr. Pappas,

This is to inform you that this office has received a report regarding a failed Title transfer inspection for your property at 10 Foretop Road, Bourne, MA 02352. This inspection was conducted by John Graci of Graci Septic Inspections, LLC on January 13, 2014.

For the reasons described below, the existing system is determined by this office to be a failed system.

*LEACHING FIELD IS NOT ADEQUATE FOR THE NUMBER OF
EXISTING BEDROOMS- CANNOT MEET HALF OF DAYS FLOW*

Pursuant to 310 CMR 15.00, Title 5, Section 15.303 and Section 15.305, you are hereby ordered to upgrade said system within two years of the date of this determination. You must contact an installer or engineer in order to conduct a percolation test which must be witnessed by the Board of Health, and then said installer or engineer will submit a plan to this office for approval.

If you have any questions, please contact this office at 508-759-0615, ext. 513.

Sincerely,

Cynthia A. Coffin, R.S., C.H.O.
Health Agent

c.c. Board of Health