



Commonwealth of Massachusetts  
Executive Office of Energy & Environmental Affairs

## Department of Environmental Protection

One Winter Street Boston, MA 02108 • 617-292-5500

Charles D. Baker  
Governor

Karyn E. Polito  
Lieutenant Governor

Matthew A. Beaton  
Secretary

Martin Suuberg  
Commissioner

### CERTIFICATION FOR GENERAL USE

Pursuant to Title 5, 310 CMR 15.000

#### Name and Address of Applicant:

Bio-Microbics, Inc.  
8450 Cole Parkway  
Shawnee, KS 66227

#### Trade name of technology and models:

FAST Treatment Systems with Nitrogen Reduction including models *MicroFAST® 0.5, 0.75, 0.9, 1.5, 3.0, 4.5, 9.0*, *HighStrengthFAST® 1.0, 1.5, 3.0, 4.5, 9.0* and *NitriFAST® 0.5, 0.75, 1.0, 1.5, 3.0, 4.5, 9.0* (all hereinafter the "System") for facilities with design flows less than 2,000 gallons per day (GPD). Schematic drawings illustrating the models and an Inspection Checklist are part of this Certification.

Transmittal Number: X232831

Date of Issuance: December 29, 2010, revised March 20, 2015

#### Authority for Issuance:

Pursuant to Title 5 of the State Environmental Code, 310 CMR 15.000, the Department of Environmental Protection (hereinafter "the Department") hereby issues this General Use Approval to: Bio-Microbics, Inc., 8450 Cole Parkway, Shawnee, KS 66227 (hereinafter "the Company"), approving the above referenced FAST technology (hereinafter "the Technology" or "System") for use in the Commonwealth of Massachusetts subject to the conditions herein. Sale and use of the Technology are subject to compliance by the Company, the Designer, the System Installer, the Operator, and the System Owner with the terms and conditions herein. Any noncompliance with the terms or conditions of this Certification constitutes a violation of 310 CMR 15.000.

David Ferris, Director  
Wastewater Management Program  
Bureau of Water Resources

March 20, 2015

Date

#### I. Purpose

This information is available in alternate format. Call Michelle Waters-Ekanem, Diversity Director, at 617-292-5751. TTY# MassRelay Service 1-800-439-2370  
MassDEP Website: [www.mass.gov/dep](http://www.mass.gov/dep)

Printed on Recycled Paper



1. Subject to the conditions of this Approval and any other local requirements, the purpose of this Approval is to allow the use of the System in Massachusetts on a General Use basis. With the necessary permits and approvals required by 310 CMR 15.000, this Certification authorizes the installation and use of the System in Massachusetts.
2. The System may be installed for residential facilities with design flow less than 2,000 GPD where a system in compliance with 310 CMR 15.000 exists on-site or could be built and for which a site evaluation in compliance with 310 CMR 15.000 has been approved by the local approving authority; or by the Department if Department approval is required by 310 CMR 15.000. This Approval allows for the use of the System as an equivalent alternative technology in accordance with 310 CMR 15.202 on facilities for nitrogen reduction in a Department designated nitrogen sensitive or limited area as defined in 310 CMR 15.214 and 15.215.

Non-residential facilities are not allowed under this approval. Non-residential facilities include properties with businesses and/or commercial establishments.

3. The technology shall meet or exceed the following effluent discharge requirements:
  - Effluent Total Nitrogen (TN) concentration of 19 mg/L (for 660 gallons per day per acre -gpda- loading) or 25 mg/L (for 550 gpda loading).
  - Effluent pH range shall be 6.0 to 9.0.
  - The System is approved for use at facilities with a maximum design flow less than 2,000 GPD.
4. The System Owner or the designated System Operator (or 'Operator') has responsibility for oversight and sampling of the System if the property served was allowed to increase the discharge rate per acre above 440 gpda in an area subject to Nitrogen Loading Limitations.

The System Owner will be required to repair, replace, modify or take any other action as required by the Department or the local approving authority, if the Department or the local approving authority determines that the System is not capable of meeting the required reduction in nitrogen in the effluent.

The Company is responsible for the approved technology as described below.

## II. General Description of the Technology and Design Standards

1. The tank containing the FAST® insert is installed between the building sewer and the soil absorption system (SAS). The SAS shall be designed and constructed in accordance with 310 CMR 15.100 - 15.279 and subject to the provisions of this Certification.
2. Technology Description - The FAST® system is an aerobic wastewater treatment system that utilizes a completely submerged fixed film process to treat organics and nitrify, and a passive recycle system for denitrification. Each model contains submerged media specific to the application. Microorganisms grow on the media and remove soluble contaminants from the wastewater, utilizing them as a source of energy for growth and production of new microorganisms. The FAST® system insert consists of a liner around the media and an airlift to provide aeration and mixing within the confines of the liner. The area outside the liner in the septic tank remains anoxic for denitrification and a passive recirculation system



moves the aerated wastewater to the outside of the liner to obtain denitrification. The aeration and circulation inside the liner are provided by a blower that pumps air into a draft tube that extends down the center of the media. Treated effluent passes out of the aerobic zone of the treatment plant through a pipe connected directly to a baffled quiescent area in the liner. Final effluent is discharged to a soil absorption system. Specific model considerations are as follows:

- The MicroFAST® 0.5, 0.75 and 0.9, HighStrengthFAST® 1.0 and NitriFAST® 0.5, 0.75 and 0.9 are installed in the second compartment of a two-compartment tank with a total liquid capacity of at least 1,500 gallons constructed in accordance with 310 CMR 15.226.
  - The MicroFAST®, HighStrengthFAST® and NitriFAST® 1.5 are installed in the second compartment of a two compartment 3000-gallon tank constructed in accordance with 310 CMR 15.226.
  - The MicroFAST®, HighStrengthFAST® and NitriFAST® 3.0 is installed in a separate tank constructed in accordance with 310 CMR 15.226 and located between a standard Title 5 septic tank, designed in accordance with 310 CMR 15.223 and 15.224, and the soil adsorption system (SAS). In this larger system, an additional recycle pump may be needed to send nitrified effluent back to the septic tank for added denitrification. Consult the Company for proper layout.
  - The NitriFAST® models can also be used for additional nitrification in series after the MicroFAST® models or HighStrengthFAST® models. In this configuration the tanks used for the NitriFAST® shall be constructed in accordance with 310 CMR 15.226 and meet the minimum dimensions and volumes required by the Company.
  - Flow equalization may also be employed prior to the FAST® system depending on the type of facility. Consult Company for proper layout.
3. All access ports and manhole covers shall be readily removable, of durable material and installed and maintained at grade to allow for maintenance of the System. No structures shall be located directly upon or above the access locations which could interfere with performance, access, inspection, pumping, or repair. Sufficient access for infrequent maintenance of the System treatment media and all other treatment works shall be evaluated, and addressed in the System design if necessary, by the designer. System control panel(s) including alarms shall be mounted in a location accessible to the operator of the System.
4. Wastewater Loading and Effluent Concentration Design Standards
- For new residential construction in an area subject to the Nitrogen Loading Limitations of 310 CMR 15.214, and the facility does not meet with the Nitrogen Loading Limitations pursuant to the aggregation provisions of 310 CMR 15.216, an increase in calculated nitrogen loading per acre is allowed for facilities with design flow less than 2000 gpd with limitations as follows:
- The design flow shall not exceed 660 gallons per day per acre (gpda) and the total nitrogen (TN) concentration in the effluent shall not exceed 19 milligrams per liter (mg/L); or



- The design flow shall not exceed 550 gallons per day per acre (gpda) and the total nitrogen (TN) concentration in the effluent shall not exceed 25 milligrams per liter (mg/L).
- TN is measured as the total of TKN (Total Kjeldhal Nitrogen), NO<sub>3</sub>-N (Nitrate nitrogen) and NO<sub>2</sub>-N (Nitrite nitrogen).

### **III. General Conditions**

1. The provisions of 310 CMR 15.000 is applicable to the use and operation of this System, the System owner and the Company, except those that specifically have been varied by the terms of this Certification.
2. Any required operation and maintenance, monitoring and testing shall be performed in accordance with a Department approved plan. Any required sample analysis shall be conducted by an independent U.S. EPA or DEP approved testing laboratory, or a DEP approved independent university laboratory, unless otherwise provided in the Department's written approval. It shall be a violation of this Certification to falsify any data collected pursuant to an approved testing plan, to omit any required data or to fail to submit any report required by such plan.
3. The facility served by the System and the System itself, shall be open to inspection and sampling by the Department and the local approving authority at all reasonable times.
4. In accordance with applicable law, the Department and the local approving authority may require the System owner to cease operation of the system and/or to take any other action as it deems necessary to protect public health, safety, welfare or the environment.
5. The Department has not determined that the performance of the System will provide a level of protection to public health and safety and the environment that is at least equivalent to that of a sanitary sewer system. Accordingly, no System shall be upgraded or expanded, if it is feasible to connect the facility to a sanitary sewer, unless as allowed by 310 CMR 15.004.
6. Design, installation, and use of the System shall be in strict conformance with the Company's DEP approved plans and specifications and 310 CMR 15.000, subject to this Certification.

### **IV. Conditions Applicable to the System Owner**

1. The System owner shall at all times have the System properly operated and maintained by a Company approved Operator in accordance with this Certification, the designer's operation and maintenance requirements and the Company's approved procedures.
2. The System is certified only in connection with the discharge of sanitary wastewater from facilities with a design flow of less than 2000 gpd. Any non-sanitary wastewater generated and/or used at the facility served by the System shall not be introduced into the System and shall be lawfully disposed of.



3. The System Owner shall provide access to the site for the System Operator to perform inspections, maintenance, repairs, responding to alarm events, field testing, and sampling as may be required by the Approval.

Operation and Monitoring Requirements

4. System effluent total nitrogen (TN) concentrations shall not exceed 19 or 25 mg/L and effluent pH shall not be less than 6.0 or more than 9.0. Field test observations of dissolved oxygen (DO) shall equal or exceed 2 mg/L and for Turbidity shall be equal or less than 40 NTU.
5. All samples shall be taken at a flowing discharge point, i.e. distribution box, pipe entering a pump chamber or other Department approved location from the treatment unit.
6. Inspection, operation and maintenance (O&M), sampling, and field testing of the System required by the Approval shall be performed by a Company approved Operator who has been certified at a minimum of Grade Level 4 (four) by the Board of Registration of Operators of Wastewater Treatment Facilities, in accordance with Massachusetts regulations 257 CMR 2.00, and is an approved Title 5 System Inspector in accordance with 310 CMR 15.340.
7. Prior to commencement of construction of the System, the System Owner shall provide to the local approving authority a copy of a signed O&M Agreement that meets the requirements of paragraph IV (8).
8. The System Owner shall maintain, at all times, an O&M Agreement with a qualified System Operator approved by the Company. The Agreement shall be at least for one year and include the following provisions:
  - a) The name of a System Operator who is an approved System Inspector in accordance with 310 CMR 15.340 and who meets any additional qualification requirements specified in the Approval;
  - b) The System Operator must inspect the Alternative System as required by paragraph IV (9) and (12);
  - c) The System Operator shall be responsible for submitting the monitoring results to the System Owner in accordance with paragraph IV (13) and to the local approving authority in accordance with paragraph IV (14); and
  - d) In the case of a System failure, an equipment failure, alarm event, components not functioning as designed, or violations of the Approval, procedures and responsibilities of the System Operator and System Owner shall be clearly defined for corrective measures to be taken immediately. The System Operator shall agree to provide written notification within five days, describing corrective measures taken, to the System Owner and the local board of health.
9. The System Owner shall comply with the following monitoring requirements if the System is subject to a TN concentration limit in accordance with paragraph II (4):



- a) Year-round installations shall be inspected and have effluent sampled for at least the TN parameter quarterly for the first year, then a minimum of twice/year thereafter, at least 5 months apart and with at least one sample taken between December 1 and March 1 of each year. Field testing shall be completed per paragraph IV (11) below, and as determined necessary by the System Operator. See DEP Field Testing Protocol at <http://www.mass.gov/dep/water/laws/policies.htm#5pols>. Wastewater flow shall be recorded at each inspection, see 'Flow Metering' paragraph IV (10).
- b) Seasonal installations shall be inspected and have effluent sampled for at least the TN parameter a minimum of twice/year. At least one sample must be taken 30 to 60 days after each seasonal occupancy begins. A second sample must be taken no less than 2 months after the first sample. Field testing shall be completed per paragraph IV (11) below, and as determined necessary by the System Operator. Wastewater flow shall be recorded at each inspection, see 'Flow Metering' paragraph IV (10).
- c) Systems in operation prior to issuance of this Approval, which have received approval of sampling reduction from the Department may continue with that System monitoring frequency.

Properties occupied at least 6 months per year are considered year-round properties. Properties occupied less than 6 months per year are considered seasonal properties.

TN is measured as the total of TKN (Total Kjeldhal Nitrogen), NO<sub>3</sub>-N (Nitrate nitrogen) and NO<sub>2</sub>-N (Nitrite nitrogen).

10. Flow Metering: Reporting of residential System water use is not required, however it is recommended the Operator record water meter readings if available at all inspections, or otherwise estimate System flow, to assist in addressing possible operational problems or issues. Flow measurement when recorded shall be based on:
  - a) actual metering data of wastewater flow to the System or actual water meter data of flow to fixtures that discharge to the wastewater system; or
  - b) actual water meter data for the total facility with either actual meter data or estimated flows for non-wastewater usage subtracted from the total facility water usage. If estimating the wastewater portion of metered water usage, the System Operator shall provide a best estimate of wastewater discharged to the System with the method of estimating, such as pump run times, occupancy rates, adjustment due to seasonal outdoor watering use, etc.; or
  - c) for Systems installed under a prior Approval that did not include a wastewater flow data reporting requirement, if no flow meters are available, the System Operator shall provide a best estimate of wastewater discharged to the System with the method of estimating, such pump run times, occupancy rate, etc.
11. Field Testing: Temperature, turbidity, pH and DO shall be measured and recorded in the field whenever the effluent is sampled for TN. See applicable sections of the Department's Field Testing Protocol at <http://www.mass.gov/dep/water/laws/policies.htm#5pols>.



12. At a minimum, the System Operator shall inspect the System:
  - a) quarterly for the first year then two times per year thereafter;
  - b) in accordance with the approved O&M manual, the Designer's operation and maintenance requirements, and the requirements of the local approving authority; and
  - c) any time there is an alarm event, equipment failure, or system failure.

Recordkeeping and Reporting

13. Within 60 days of any site visit, the System Operator shall submit an O&M report and inspection checklist to the System Owner and the Company. It is recommended the System Owner and Company maintain copies of these items for possible Department audit. The O&M report shall include, at a minimum:
  - a) for a System failing, any corrective actions taken;
  - b) wastewater analyses, wastewater flow data, field testing results and inspection checklists;
  - c) any violations of the Approval;
  - d) any determinations that the System or its components are not functioning as designed or in accordance with the Company specifications; and
  - e) any other corrective actions taken or recommended.
14. By February 15th of each year the System Owner or the System Operator if designated by the owner, shall submit to the local approving authority all monitoring results with all O&M reports and inspection checklists completed by the System Operator during the previous 12 months.
15. Upon determining that the System has failed, as defined in 310 CMR 15.303, the System Operator shall notify the System Owner immediately.
16. Upon determining that the System has failed, as defined in 310 CMR 15.303, the System Owner and the System Operator shall be responsible for the notification of the local approving authority within 24 hours of such determination.
17. The System Owner shall notify the Approving Authority and the Company in writing within seven days of any cancellation, expiration or any other change in the terms and/or conditions of the O&M Agreement required by Paragraph IV (8).
18. Violations of the TN concentration in the System effluent shall not constitute a failure of the System for the purposes of 24-hour notification or 5-day written reporting as required in Paragraphs IV (16) and (8).
19. The System owner shall provide a copy of this Approval, prior to the signing of a purchase and sale agreement for the facility served by the System or any portion thereof, to the proposed new owner.



20. The System owner shall furnish the Department any information that the Department requests regarding the System, within 21 days of the date of receipt of that request.
21. Prior to issuance of a Certificate of Compliance of the System, and after recording and/or registering the Notice required by 310 CMR15.287(10), the System Owner shall provide to the Local Approving Authority a copy of: (i) a certified Registry copy of the Notice bearing the book and page/or document number; and (ii) if the property is unregistered land, a Registry copy of the System Owner's deed to the property, bearing a marginal reference on the System Owner's deed to the property. The Notice to be recorded shall be in the form of the Notice provided by the Department.
22. Prior to signing any agreement to transfer any or all interest in the property served by the System, or any portion of the property, including any possessory interest, the System Owner shall provide written notice of all conditions contained in the Approval to the transferee(s). Any and all instruments of transfer and any leases or rental agreements shall include as an exhibit attached thereto and made a part of thereof a copy of the Approval for the System. The System Owner shall send a copy of such written notification(s) to the Local Approving Authority within 10 days of giving such notice to the transferee(s).

**V. Conditions Applicable to the Company**

1. The Company shall notify the Director of the Wastewater Management Program at least 30 days in advance of the proposed transfer of ownership of the technology for which this Certification is issued. Said notification shall include the name and address of the proposed new owner and a written agreement between the existing and proposed new owner containing a specific date for transfer of ownership, responsibility, coverage and liability between them. All provisions of this Certification applicable to the Company shall be applicable to successors and assigns of the Company, unless the Department determines otherwise.
2. The Company shall develop maintain and update as necessary the following: minimum installation requirements; an operating manual, including information on substances that should not be discharged to the System; a maintenance checklist; and a recommended schedule for maintenance of the System consistent with the Department's requirements essential to consistent successful performance of the installed Systems.
3. The Company shall institute and maintain a program of operator training and continuing education. The Company shall maintain and annually update, and make available the list of qualified operators by February 15th and make the list known to local approving authorities, the Department and to users of the technology.
4. The Company shall furnish the Department any information that the Department requests regarding the System, within 21 days of the date of receipt of that request.
5. The Company shall include copies of this Certification and the procedures described in Section V (3) with each System that is sold. In any contract executed by the Company for distribution or re-sale of the System, the Company shall require the distributor or re-seller to provide each purchaser of the System with copies of this Certification and the procedures described in Section V (3).



6. A copy of the wastewater analyses, wastewater flow data, field testing results, and System Operator O&M reports and inspection checklists from each installed System shall be maintained by the Company or its designee for possible Department audit.
7. If the Company wishes to continue this Certification after its expiration date, the Company shall apply for and obtain a renewal of this Certification. The Company shall submit a renewal application at least 180 days before the expiration date of this Certification, unless written permission for a later date has been granted in writing by the Department. This Certification shall continue in force until the Department has acted on the renewal application.

#### **VI. Conditions Applicable to the System Designer**

1. Upon submission of an application for a DSCP, the Designer shall provide to the local approving authority:
  - a) a certification, signed by the owner of record for the property to be served by the System, stating that the property owner:
    - i) has been provided a copy of the Approval, the Owner's Manual, and the Operation and Maintenance Manual, if applicable, and the Owner agrees to comply with all terms and conditions;
    - ii) has been informed of all the owner's costs associated with the operation including, when applicable: power consumption, maintenance, sampling, recordkeeping, reporting, and equipment replacement;
    - iii) understands the requirement for a service contract;
    - iv) agrees to fulfill his responsibilities to provide a Deed Notice as required by 310 CMR 15.287(10) and the Approval;
    - v) agrees to fulfill his responsibilities to provide written notification of the Approval to any new owner, as required by 310 CMR 15.287(5);
    - vi) if the design does not provide for the use of garbage grinders, the restriction is understood and accepted;
    - vii) if the design is for an upgrade of failed or nonconforming system, the System Owner has been provided a copy of the evaluation of the existing system;
    - viii) whether or not covered by a warranty, the System Owner understands the requirement to repair, replace, modify or take any other action as required by the Department or the local approving authority, if the Department or the local approving authority determines that the Alternative System is not capable of meeting the performance standards; and
  - b) a certification, signed by the Designer that the design conforms to the Approval with Conditions and 310 CMR 15.000.

#### **VII. Reporting**

1. All notices and documents required to be submitted to the Department by this Certification shall be submitted to:




Director  
Wastewater Management Program  
Department of Environmental Protection,  
One Winter Street - 5th floor  
Boston, Massachusetts 02108

**VIII. Rights of the Department**

1. The Department may suspend, modify or revoke this Certification for cause, including, but not limited to, non-compliance with the terms of this Certification, non-payment of the annual compliance assurance fee, for obtaining the Certification by misrepresentation or failure to disclose fully all relevant facts or any change in or discovery of conditions that would constitute grounds for discontinuance of the Certification, or as necessary for the protection of public health, safety, welfare or the environment, and as authorized by applicable law. The Department reserves its rights to take any enforcement action authorized by law with respect to this Certification and/or the System against the owner or operator of the System and/or the Company.


Transmittal: X232831 (formerly W101238)





# NOTES

1. Blower piping to FAST® may not exceed 100 FT [30.5m] total length and use 4 elbows maximum. For distances greater than 100 FT [30.5m] - consult factory. Blower must be located above flood/standing water levels on a concrete base.
2. Vent to be located above finish grade or higher to avoid infiltration. Cap with vent grate with at least V2 sq.in. of open surface area. Secure with stainless steel screws (see sheet 3 of 3 FAST Details.)  
or  
Run vent to desired location and cover opening with vent grate with at least V2 sq.in. of open surface area. Secure with stainless steel screws. Vent piping must not allow excess moisture build up or back pressure.
3. All apertures to FAST® (e.g. tank pump outs, etc.) must conform to all country, state, province, and local plumbing and electrical codes. The blower control system is provided by Bio-Microbics, Inc.
4. Either the influent pipe tee shall be fitted with a pipe cap or the baffle separating the two zones shall be extended to the top of the tank. If choosing to use the pipe cap; drill a 1/4" [0.6cm] vent hole in the cap and the baffle shall be at least 3" [8] higher than the water level as shown on the drawing.
5. All inspection, viewing and pump out ports must be secured to prevent accidental or unauthorized access
6. Tank, anchors, piping, conduit, blower housing pad and vents are provided by others.
7. All piping and ancillary equipment installed after FAST® must not impede or restrict free flow of effluent.
8. No more than 4 FT [1.2m] of fill may be placed over unit lid. Refer to installation manual for more details.
9. See sheet 3 of 4 for required dimensions.





DO NOT SCALE		UNLESS NOTED DIMENSIONS ARE IN INCHES [CENTIMETERS] TOLERANCES ± 0.02 IN/IN [± 0.05 CM/CM]	
BIO-MICROBICS <sup>®</sup>		INCORPORATED	
MA 0.5-1.5 FAST Units			

THE INFORMATION CONTAINED IN THIS DRAWING IS THE SOLE PROPERTY OF BIO-MICROBICS, INC. ANY REPRODUCTION IN PART OR AS A WHOLE WITHOUT THE WRITTEN PERMISSION OF BIO-MICROBICS, INC. IS PROHIBITED. DESIGN AND INVENTION RIGHTS ARE RESERVED. IN THE INTEREST OF TECHNOLOGICAL ADVANCEMENT, ALL PRODUCTS ARE SUBJECT TO DESIGN AND OR MATERIAL CHANGE WITHOUT NOTICE.

NAME	DATE	SIZE	DRAWING NUMBER	SHEET
MADE	12/18/2006	A	FAST® with lid	1 OF 4
CHECKED BY	4/19/2011		REVISED 4/19/2011	
			REV. INC-4-D	






- NOTES**
1. Blower piping to FAST® may not exceed 100 FT [30.5m] total length and use 4 elbows maximum. For distances greater than 100 FT [30.5m] - consult factory. Blower must be located above flood/standing water levels on a concrete base.
  2. Vent to be located above finish grade or higher to avoid infiltration. Cap with vent grate with at least **V2** sq in. of open surface area. Secure with stainless steel screws (see sheet 3 of 3 FAST Details.)  
or  
Run vent to desired location and cover opening with vent grate with at least **V2** sq in. of open surface area. Secure with stainless steel screws. Vent piping must not allow excess moisture build up or back pressure.
  3. All apertures to FAST® (e.g. tank pump outs, etc.) must conform to all country, state, province, and local plumbing and electrical codes. The blower control system is provided by Bio-Microbics, Inc.
  4. Either the influent pipe tee shall be fitted with a pipe cap or the baffle separating the two zones shall be extended to the top of the tank. If choosing to use the pipe cap; drill a 1/4" [0.6cm] vent hole in the cap and the baffle shall be at least 3" [8] higher than the water level as shown on the drawing.
  5. All inspection, viewing and pump out ports must be secured to prevent accidental or unauthorized access
  6. Tank, anchors, piping, conduit, blower housing pod and vents are provided by others.
  7. All piping and ancillary equipment installed after FAST® must not impede or restrict free flow of effluent.
  8. **H1 Min** Height may be reduced, consult factory and reference "Short-FASTModule-Procedure.pdf."
  9. See sheet 3 of 4 for required dimensions.



Unit Size	A MIN	B MIN	V1 MIN	V2 MIN	L1	L2	L3	W1 MIN	W2	W3	H1 MIN
0.5	500	1000	3"	7.1 in sq	59.5"	54"	29.75"	31.25"	25"	15.125"	16.375"
0.75	500	1000	3"	7.1 in sq	60"	54"	31.5"	44.25"	37"	21.5	16.375"
0.9	500	1000	3"	7.1 in sq	59"	54"	31.25"	54.5"	49"	26.625	16.375"
1.0	500	1000	4"	9 in sq	59"	54"	31.25"	54.5"	49"	26.625	16.375"
1.5	750	2000	4"	9 in sq	83.5"	75.75"	42.875"	55.75"	49"	27.625	16.25"

A MIN	Settling Zone (MIN Liquid Capacity)
B MIN	FAST® Chamber (MIN Liquid Capacity)
V1 MIN	Vent Diameter (MIN)
V2 MIN	Vent grate open area (MIN).
L1	FAST® Length and MIN Tank Length
L2	Length of tank opening for hanging FAST®
L3	FAST® Length from edge of liner to center of airline.
W1 MIN	FAST® MIN Tank Width.
W2	Width of tank opening for hanging FAST®.
W3	FAST® Width from edge of liner to center of airline.
H1 MIN	Clearance from center of outlet to inside top of tank (for feet install only)

THE INFORMATION CONTAINED IN THIS DRAWING IS THE SOLE PROPERTY OF BIO-MICROBICS INC. ANY REPRODUCTION IN PART OR AS A WHOLE WITHOUT THE WRITTEN PERMISSION OF BIO-MICROBICS INC. IS PROHIBITED. DESIGN AND INVENTION RIGHTS ARE RESERVED. IN THE BIO-MICROBICS © 2011 INTEREST OF TECHNOLOGICAL ADVANCEMENT, ALL PRODUCTS ARE SUBJECT TO DESIGN AND OR MATERIAL CHANGE WITHOUT NOTICE.


DO NOT SCALE UNLESS NOTED DIMENSIONS ARE IN INCHES (CENTIMETERS) TOLERANCES ± 0.02 IN/IN [± 0.05 CM/CM]			
MA 0.5-1.5 FAST Units			
WEIGHT	DATE	SIZE	DRAWING NUMBER
NAME	DATE	A	Chart
DRAWN CTC	12/18/2006		
CHECKED PF	4/19/2011		REV. INK4-D
			SHEET 3 OF 4






## Notes

1. Secure leg extension to the FAST® unit by placing two screws on each side of the leg extension (4 screws per foot are included).
2. Cut 4" schd. 40 PVC pipe (not included) to obtain the desired height. Minimum pipe length of 6 1/8" [15.56cm]. For heights greater than 18" [45.7cm] use schd. 80 PVC pipe (not included). Consult factory for extending leg beyond 36" [9cm].
3. Anchor the leg extensions to the tank with non-corrosive hardware (not included) at the provided mounting points.
4. The air supply line into the FAST® unit must be secured to prevent vibration induced damage. The air supply line should be secured with a non-corrosive clamp every 2' MIN.
5. Tank, anchors, piping conduit, blower housing pad, and tank vents are provided by others.

## Minimum leg extension assembly see note 2, 3, & 4



## FAST® Vent Option



## Alternate Air Supply Option

DO NOT SCALE  
UNLESS NOTED  
DIMENSIONS  
ARE IN INCHES  
(CENTIMETERS)  
TOLERANCES  
± 0.02 IN/IN  
[± 0.05 CM/CM]

MA 0.5-1.5 FAST Units

**BIO-MICROBICS**  
INCORPORATED

THE INFORMATION CONTAINED IN THIS DRAWING IS THE SOLE PROPERTY OF BIO-MICROBICS INC. ANY REPRODUCTION IN PART OR AS A WHOLE WITHOUT THE WRITTEN PERMISSION OF BIO-MICROBICS INC. IS PROHIBITED. DESIGN AND INVENTION RIGHTS ARE RESERVED. IN THE INTEREST OF TECHNOLOGICAL ADVANCEMENT, ALL PRODUCTS ARE SUBJECT TO DESIGN AND OR MATERIAL CHANGE WITHOUT NOTICE.

WEIGHT	NAME	DATE	SIZE	DRAWING NUMBER	SHEET
	NAME	DATE	A	FAST® Details	4 OF 4
CHECKED PF	4/19/2011			REV. IN404-D	



# NOTICE OF ALTERNATIVE SEWAGE DISPOSAL SYSTEM

M.G.L. c. 21A, § 13 and 310 CMR 15.0287(10)

## ADDRESS OF PROPERTY SERVED BY ALTERNATIVE SYSTEM:

128 Emmons Road, Bourne, MA 02553

## TITLE REFERENCE FOR PROPERTY SERVED BY ALTERNATIVE SYSTEM *[check and complete each that applies]:*

- ☒ Deed recorded with the Barnstable Registry of Deeds in Book 33577, Page 274  
☐ Certificate of Title No. \_\_\_\_\_ issued by the Land Registration Office of the \_\_\_\_\_  
Registry District  
☐ Source of title other than by deed \_\_\_\_\_

## NAME(S) OF OWNER OF PROPERTY SERVED BY ALTERNATIVE SYSTEM:

Jonathan Levitt and Marni Levitt

## OWNER(S) MAILING ADDRESS:

128 Emmons Road, Bourne, MA

*[If Alternative System Owner(s) is other than Property Owner(s), complete the following:]*

Alternative System Owner Name: \_\_\_\_\_

Alternative System Owner Address: \_\_\_\_\_

Alternative System Owner Telephone Number: \_\_\_\_\_ E-mail Address: \_\_\_\_\_

WHEREAS, Section 15.280 of Title 5 of the State Environmental Code ("Approval of Alternative Systems"), provides for the Massachusetts Department of Environmental Protection (the "Department") to approve or certify, as appropriate, all proposals to construct, upgrade or replace on-site sewage disposal systems using alternative systems;

WHEREAS, owners and/or operators of approved or certified alternative systems are subject to general conditions, as specified in Section 15.287 of Title 5 of the State Environmental Code, 310 CMR 15.287, and may be subject to special conditions, as specified in the Department's approvals or certifications; such general and special conditions potentially including, without limitation, requirements relating to the use of trained operators, periodic inspections, maintenance, sampling, reporting and/or recordkeeping;

WHEREAS, the owners and/or operators this alternative system acknowledges and agrees to comply with the provisions of all of the Bourne Board of Health Alternative Septic System Regulations and any other conditions for the existence of the system;







\_\_\_\_\_, ss

On this \_\_\_\_ day of \_\_\_\_\_, 20\_\_\_\_, before me, the undersigned notary public, personally appeared Jonathan Levitt and Marni Levitt (name of document signer), proved to me through satisfactory evidence of identification, which were \_\_\_\_\_, to be the person whose name is signed on the preceding or attached document, and acknowledged to me that (he) (she) signed it voluntarily for its stated purpose.

\_\_\_\_\_  
(official signature and seal of notary)

\_\_\_\_\_  
*[Complete the following Property Owners Consent if Alternative System Owner is other than the Property Owner:]*

CONSENTED TO:

\_\_\_\_\_  
[Property Owner(s)]

Print Name(s):  
\_\_\_\_\_

COMMONWEALTH OF MASSACHUSETTS

\_\_\_\_\_, ss

On this \_\_\_\_ day of \_\_\_\_\_, 20\_\_\_\_, before me, the undersigned notary public, personally appeared \_\_\_\_\_ (name of document signer), proved to me through satisfactory evidence of identification, which were \_\_\_\_\_, to be the person whose name is signed on the preceding or attached document, and acknowledged to me that (he) (she) signed it voluntarily for its stated purpose.

\_\_\_\_\_  
(official signature and seal of notary)

\_\_\_\_\_  
Approved and Accepted By:

\_\_\_\_\_  
Agent of the Board of Health  
Town of Bourne