



# TOWN OF BOURNE

BOARD OF HEALTH

BOURNE, MASS.



CYNTHIA A. COFFIN, HEALTH AGENT

Pursuant to Chapter 111, s. 31, Mass. General Laws, the Bourne Board of Health voted at its regular meeting held on September 28, 1988, to amend the 150 foot setback requirement for all leaching facilities from a watercourse, approved June 1, 1988, to be as follows:

## Section 1.

Having determined that contaminant transport rates in glacial outwash soils may be up to 2.3 feet per day (LeBlanc - USGS report 82-274), a 150 foot setback will be required for all leaching facilities from the edge of a wetland resource or watercourse, as defined in 310 CMR 15.01 Title V. Setback distance shall be measured during periods of highest ground or surface water conditions. The Board of Health may grant a variance from the 150 foot setback requirement, based upon satisfactory documentation prepared by a hydrogeologist or professional sanitary engineer. In addition, a hydrogeologic study, prepared by a hydrogeologist or professional sanitary engineer, will be required by the Board of Health for all leaching facilities within 100 feet of a wetland or watercourse, as defined by 310 CMR 15.01, Title V. In no case shall a septic system leaching facility be placed within 75 feet of a wetland or watercourse, except in cases of repair or extreme hardship.

## Section 2. Definitions

Highest groundwater shall be defined as the maximum water table elevation, as determined by the USGS monitoring well data provided by the Cape Cod Planning and Economic Development Commission. The USGS computer model may be used to determine maximum groundwater elevation, except in coastal zones, where highest groundwater shall be determined at periods of high tide, including spring and moon tides.

Highest surface water shall be defined as vernal pond elevations, or, in a coastal zone, maximum high water at high tide (including moon and spring tides).

Extreme hardship shall be defined as loss or damage to structure or septic system due to fire, flood, acts of nature, or land taking (by eminent domain).

Bourne Board of Health

Haydon S. Coggeshall, Chairman  
Steven A. MacNally, Vice-Chairman  
Thomas E. Fantozzi, Secretary  
Arthur M. Handy  
Robert J. Kilduff

Effective Date  
October 19, 1988

## 150 FOOT SETBACK REG

### TOWN OF BOURNE BOARD OF HEALTH

#### BOURNE, MASS.

Pursuant to Chapter 111, s. 31, Mass. General Laws, the Bourne Board of Health voted at its regular meeting September 23, 1983, to amend the 150 foot setback requirement for all leaching facilities from a watercourse, approved June 1, 1988, to be as follows:

#### Section 1.

Having determined that contaminant transport rates in glacial outwash soils may be up to 2.3 feet per day (LeBlanc - USGS report 82-274), a 150 foot setback will be required for all leaching facilities from the edge of a wetland resource or watercourse, as defined in 310 CMR 15.01 Title V. Setback distance shall be measured during periods of highest ground or surface water conditions. The Board of Health may grant a variance from the 150 foot setback requirement, based upon satisfactory documentation prepared by a hydro geologist or professional sanitary engineer. In addition, a hydro geologic study, prepared by a hydro geologist or professional sanitary engineer, will be required by the Board of Health for all leaching facilities within 100 feet of a wetland or watercourse, as defined by 310 CMR 15.01, Title V. In no case shall a septic system leaching facility be placed within 75 feet of a wetland or watercourse, except in cases of repair or extreme hardship.

#### Section 2. Definitions

Highest groundwater shall be defined as the maximum water table elevation, as determined by the USGS monitoring well data provided by the Cape Cod Planning and Economic Development Commission. The USGS computer model may be used to determine maximum groundwater elevation, except in coastal zones, where highest groundwater shall be determined at periods of high tide, including spring and moon tides.

Highest surface water shall be defined as vernal pond elevations, or, in a coastal zone, maximum high water at high tide (including moon and spring tides).

Extreme hardship shall be defined as loss or damage to structure or septic system due to fire, flood, acts of nature, or land taking (by eminent domain).

## HYDROGEOLOGIC STUDY

### BOARD OF HEALTH TOWN OF BOURNE

Pursuant to Chapter 111 Section 31 of Mass. General Laws, the Bourne Board of Health, at its regular meeting of May 24, 1995 voted to amend its regulation of September 28, 1988, effective date October 19, 1988 by changing the 4th sentence of said regulation to read as follows:

In addition, a hydrogeology study, prepared by a hydro geologist or professional sanitary engineer, will be required by the Board of Health for all leaching facilities within 100 feet of a wetland or watercourse as defined by 310 CMR 15.01, 1978 Title 5.

Bourne Board of Health