



**Town of Bourne**  
Fire/Rescue & Emergency  
Services  
51 Meetinghouse Lane  
Sagamore Beach, MA 02562  
508-759-4412



To: Cassie Hammond  
From: David S. Pelonzi, Assistant Chief  
Date: 03/29/2021  
Subject: ZBA Hearing, 04/07/2021

I have reviewed the projects on the agenda and have the following comments:

1. Cape View Way:

- a. I will need to know the physical address and work with engineering on unit numbering
- b. I approved the previously submitted fire vehicle access plan, but will need a formal copy with the responsible registered professional engineer's seal and signature.
- c. I will need a complete set of Tier I documents, as outlined in the State Building Code, attached to the building permit application.
- d. Testing will need to be conducted to determine if the building will need amplification for emergency responder radio coverage.
- e. At least one Knox Box will be required.