

Photometric Study - Run 2 - King Luminare & Heper

Luminaire Schedule												
Symbol	Label	Qty	Description	Arrangement	IES Class	CCT	Arm	MH	LLF	Lumens	Watts	Filename
	M	2	King Luminaire: K723-P4FL-III-25-3K	SINGLE	Type III	3000K	2.5	15	0.900	3717	27.7	0700sp4fl3x02530xxe.ies
	N	8	King Luminaire: K723-P4FL-III-25-3K	SINGLE	Type III	3000K	2.5	12	0.900	3717	27.7	0700sp4fl3x02530xxe.ies
	P	5	King Luminaire: K723-P4FL-IV-40-3K	SINGLE	Type IV	3000K	2.5	15	0.900	4966	42.5	0700NP4FL4X04030XXE.IES
	P2	6	King Luminaire: K723-P4FL-IV-40-3K	BACK-BACK	Type IV	3000K	2.5	15	0.900	4966	42.5	0700NP4FL4X04030XXE.IES
	R	13	Heper: Troli S Bollard, 3K	SINGLE	Type IV	3000K	0	1	0.900	479	10	LB7032.693-US-SYM-3L-700-830.ies

Calculation Summary - Area							
Label	CalcType	Units	Avg	Max	Min	Avg/Min	Max/Min
Driveway	Illuminance	Fc	2.1	5.7	0.4	5.1	14.3
Parking A	Illuminance	Fc	1.5	5.4	0.3	5.1	18.0
Parking B	Illuminance	Fc	1.4	3.7	0.5	2.7	7.4
Patio	Illuminance	Fc	2.6	16.2	0.4	6.4	40.5

NOTE:
▲ = King Luminaire HSS4, 6" House Side Shield installed

