



Town of Bourne
Fire/Rescue & Emergency
Services
51 Meetinghouse Lane
Sagamore Beach, MA 02562
508-759-4412



To: Cassie Hammond
From: David S. Pelonzi, Assistant Chief
Date: 09/10/2021
Subject: Cape View Way

Based on updated information I have received on the project above, I have the following comments to add to previous fire department comment:

- The new fire flow test report confirmed the previous test results. The water supply for structure will be sufficient.
- Even with site modifications, the updated emergency vehicle access plan still provides sufficient emergency access for fire department vehicles.
- This department does not require a post-indicator valve for the fire sprinkler system. NFPA 24-10 addresses valves controlling water supply for fire suppression. It will be up to the registered design professional to determine the appropriate valves for the system.